

Issued by	NMi Certin B.V. Hugo de Grootplein 1 3314 EG Dordrecht The Netherlands
In accordance with	Paragraph 8.1 of the European Standard on Metrological aspects of non-automatic weighing instruments EN 45501:1992/AC:1993 and by application of the OIML International Recommendation R 60 (Edition 2000).
Manufacturer	Zhonghang Electronic Measuring Instruments Co., Ltd.(ZEMIC) XinYuan Rd. North Zone of EDZ, Hanzhong, 723000 Shaanxi China
In respect of	A shear beam load cell , with strain gauges, tested as a part of a weighing instrument. Manufacturer : Zhonghang Electronic Measuring Instruments Co., Ltd. (ZEMIC) Type : BM8H-Cx-xx-xx-xx Series
Characteristics	E_{max} : 2000 kg up to and including 5000kg Accuracy class : C In the description number TC8104 revision 0 further characteristics are described.
Description and documentation	The load cell is described in the description number TC8104 revision 0 and documented in the documentation folder TC8104-1, appertaining to this test certificate.
Remarks	Summary of the test involved: see Appendix number TC8104 revision 0.

Issuing Authority **NMi Certin B.V. Notified Body number 0122**
 25 April 2012

C. Oosterman
 Head Certification Board

NMi Certin B.V.
 Hugo de Grootplein 1
 3314 EG Dordrecht
 The Netherlands
 T +31 78 6332332
 certin@nmi.nl
 www.nmi.nl

This document is issued under the provision that no liability is accepted and that the applicant shall indemnify third-party liability.
 The designation of NMi Certin BV.as Notified Body can be verified at <http://ec.europa.eu/enterprise/newapproach/nando/>

Parties concerned can lodge objection against this decision, within six weeks after the date of submission, to the general manager of NMi (see "Regulation objection and appeal against decisions of NMi" www.nmi.nl)

Reproduction of the complete document only is permitted

1 General information about the load cell

All properties of the load cell, whether mentioned or not, may not be in conflict with the standard mentioned in the test certificate.

1.1 Essential parts

Description	Drawing number	Rev.	Remarks
BM8H Load Cells Catalogue for using	8104/0-01	0	Mechanical/ Electrical

Cable:

- The load cell is provided with a 4-wire system:
 - The cable length is mentioned on the load cell, see chapter "Naming example" in the BM8H Load cells Catalogue for using;
 - The cable length shall not be modified.
- The load cell is provided with a 6-wire system (= "Remote-sensing"):
 - The cable length is not limited.
- The cable should be a shielded cable, the shield is not connected to the load cell.

1.2 Essential characteristics

Type		BM8H-Cx-xx-xx-xx Series
Load cell construction		Shear beam
Humidity classification		CH
Fraction p_{ic}		0,7
Temperature range		-10 °C / +40 °C
Maximum capacity	E_{max}	2000 kg up to and including 5000 kg
Accuracy class		C
Maximum number of load cell verification intervals	n_{max}	3000
Ratio of minimum LC verification interval	$Y = E_{max} / v_{min}$	15000
Ratio of minimum dead load output return	$Z = E_{max} / 2 * DR$	3000

The characteristics for n_{max} and Y can be reduced separately. Z is proportional or equal to n_{max} .



Description

Number **TC8104** revision 0
Project number 12200100
Page 3 of 4

Each produced load cell is supplied with information about its characteristics.

Minimum dead load	: 0 kg
Safe overload	: 150% of E_{\max}
Rated Output	: 2 mV/V \pm 0,02 mV/V
Input impedance	: 1000 Ω \pm 10 Ω
Output impedance	: 1004 Ω \pm 5 Ω
Recommended excitation	: 5-12 V DC/AC
Excitation maximum	: 18 V DC/AC
Transducer material	: Stainless steel
Atmospheric protection	: Hermetically welded

1.3 Essential shapes

The load cell is built according to drawing:

- "BM8H Load Cells Catalogue for using", drawing number 8104/0-01.

The data plate is secured against removal by sealing or will be destroyed when removed. The data plate mentions at least the information and markings as described in the OIML R60 document. In the countries where it is mandatory the load cell should bear this test certificate number: TC8104.

Securing:

The connecting cable of the load cell or the junction box is provided with possibility to seal.

Tests performed for this test certificate:

Test	Institute	type, version, remarks
Temperature test and repeatability (20, 40, -10 and 20 °C)	NMi Certin B.V.	BM8H-C3-2T-6B
Temperature effect on minimum dead load output (20, 40, -10 and 20 °C)	NMi Certin B.V.	BM8H-C3-2T-6B
Creep (20, 40 and -10 °C)	NMi Certin B.V.	BM8H-C3-2T-6B
Minimum dead load output return (20, 40 and -10 °C)	NMi Certin B.V.	BM8H-C3-2T-6B
Barometric pressure effects at room temperature	NMi Certin B.V.	BM8H-C3-2T-6B
Damp heat, cyclic: marked CH (or not marked)	NMi Certin B.V.	BM8H-C3-2T-6B